

# Energy performance certificate (EPC)

2 Thompsons Terrace  
Carleton  
SKIPTON  
BD23 3DU

Energy rating

C

Valid until: 12 July 2032

Certificate number: 7202-7623-3700-0077-5296

Property type Mid-terrace house

Total floor area 60 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be B.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		89   B
69-80	C	70   c	
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Sandstone or limestone, as built, no insulation (assumed)	Very poor
Roof	Pitched, 100 mm loft insulation	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in 67% of fixed outlets	Good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

## Primary energy use

The primary energy use for this property per year is 239 kilowatt hours per square metre (kWh/m<sup>2</sup>).

## Environmental impact of this property

This property's current environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 2.6 tonnes of CO<sub>2</sub>

This property's potential production is 1.0 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## Improve this property's energy rating

Follow these steps to improve the energy rating and score.

Step	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£92
2. Low energy lighting	£15	£16
3. Solar water heating	£4,000 - £6,000	£22

Step	Typical installation cost	Typical yearly saving
4. Solar photovoltaic panels	£3,500 - £5,500	£322

## Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

Estimated yearly energy cost for this property	£596
--	------

Potential saving if you complete every step in order	£129
--	------

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used
-----------------	-----------------------

Space heating	7354 kWh per year
---------------	-------------------

Water heating	1774 kWh per year
---------------	-------------------

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Loft insulation	354 kWh per year
-----------------	------------------

Solid wall insulation	2113 kWh per year
-----------------------	-------------------

## Saving energy in this property

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](https://www.gov.uk/improve-energy-efficiency).

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Ross Knight
Telephone	08455191250
Email	<a href="mailto:info@boxpropertysolutions.com">info@boxpropertysolutions.com</a>

### Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO032866
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### Assessment details

Assessor's declaration	No related party
Date of assessment	13 July 2022
Date of certificate	13 July 2022
Type of assessment	<a href="#">RdSAP</a>

---